

## SECTION 3

### 3.12 METERS:

Meters and appurtenances are discussed in detail in 6.14 through 6.27. Meters which are read for billing purposes by Denver Water shall be owned by, and installed at the expense of, the property owner served by such meter. The exception occurs when the Board installs meters at its own expense to convert unmetered services to metered services. In this case, the meters are owned by the Board.

- A. Inside Setting Installation: All inside meter settings must be equipped with an approved meter, and a remote-mounted Itron Model 40W ERT with 20-foot electric cable.
- B. Outside Setting, Vault Installation: All outside, meter settings in vaults, 1-1/2 inch and larger, must be equipped with an approved meter and an Itron Model 40W-1 pit ERT for each meter register. All drawings must be approved by Denver Water's Meter Shop prior to installation.
- C. Outside Setting, Pit Installation: All outside meter settings in pits must be equipped with an approved meter with a direct read register and an Itron Model 40W-1 pit ERT (5/8 inch, 3/4 inch, and one inch only), mounted in accordance with Denver Water's standards.